



GENERAL ADMINISTRATIVE DEPARTMENT

Ref No : JKGB/GAD/2026-27/4166

Date:21.08.2026

CORRIGENDUM

This is for information of all the bidders that following amendments have been made in tender document (JKGB/GAD/UPS/2026-27/3803 Dated 10.08.2026) regarding Rate Contract for the Supply, Installation, Testing, and Commissioning of UPS systems with lithium-ion batteries and built-in isolation transformers at Branches / Offices of Jammu and Kashmir Grameen Bank across the UT of J&K and UT of Ladakh.

Sr. No	Page number/ Clause number	Existing Clause	Revised clause
1	Clause D (SCHEDULE FOR TENDER PROCESS) Last Date of time for Bid Submission at Page No 3 of tender document	31.08.2026 upto 05:00 P.M.	10.09.2026 (Thursday) Upto 05:00 PM
2	Clause D (SCHEDULE FOR TENDER PROCESS) Technical Bid opening date at Page No 3 of tender document	01.09.2026 at 03:00 P.M at Jammu and Kashmir Grameen Bank Head Office, , Near Fruit Complex Narwal-180006, Jammu	14.09.2026 at 03:00 P.M at Jammu and Kashmir Grameen Bank Head Office, , Near Fruit Complex Narwal-180006, Jammu
3	Clause 33 (a) (Supply Order) mentioned at Page No 11 of tender document	L-1 Bidder has to supply, install, test and commission the UPS of 3KVA/5KVA with lithium ion batteries and built in isolation at Branches / Offices of the bank within 10 days from the date of the issuance of Supply/purchase order.	L-1 Bidder has to supply, install, test and commission the UPS of 3KVA/5KVA with lithium ion batteries and built in isolation at Branches / Offices of the bank within 30 days from the date of the issuance of Supply/purchase order.
4	Preferred Brand/Make under Technical Specification(Annexure-1) at Page No.17 of tender document	Eaton/ Hitachi/ Micro-tek/ Luminous/ E&C Acenta/APC by Schneider Electric/ Delta Electronics/ Consul Neowatt/vertiv/Prostarm	Eaton/ Hitachi/ Micro-tek/ Luminous/ E&C Acenta/APC by Schneider Electric/ Delta Electronics/ Consul Neowatt/vertiv/Prostarm/ Uniline/Numeric-Legrand
5	DC requirement under Technical Specification Annexure-1 (Sr. No. 21) Page No.17 of tender document	96V in case of 3KVA and 192V in case of 5KVA	72/96V in case of 3KVA and 192V in case of 5KVA

The tentative list of make of inverter, Inverter Batteries for Buy Back and tentative list of branches/sites where UPS to be supplied is enclosed as Annexure-1.

Response to Pre-bid queries and clarifications raised by various bidders is enclosed as Annexure-2.

All other clauses, terms & conditions of the RFP remains same as mentioned in the RFP document published vide Ref.No. JKGB/GAD/UPS/2026-27/3803 Dated 10.08.2026.

Sd/-

HOD (GAD)

Jammu and Kashmir Grameen Bank